



1. STATION REQUIRES (1) 120 VOLT, 5 AMP CIRCUIT TO THE SERVICE DISCONNECT FACTORY WIRED INSIDE UNIT (SUPPLIED & WIRED BY OTHERS).
2. STATION REQUIRES (1) ETHERNET CONNECTION TO THE FACTORY WIRED BISCUIT INSIDE UNIT (SUPPLIED & WIRED BY OTHERS).
3. STATION IS FLOOR MOUNTED. LEGS ARE ADJUSTABLE IN 1" INCREMENTS, RANGING FROM 24.23"- 28.23". VERIFY WITH OWNER ANY MILLWORK THAT MIGHT INTERFERE WITH STATION HEIGHT. RECOMMENDED LEG SETTING HEIGHT IS 26.23" (AS SHOWN).
4. TOUCH SCREEN CONTROL CENTERLINE HEIGHT IS 41.28" (AS SHOWN) & CARRIER STORAGE BINS CENTERLINE HEIGHT IS 48" (AS SHOWN).
5. ROUGH OPENING IS 33" WIDE X 22" DEEP X CEILING HEIGHT. DO NOT ENCLOSE OR DRYWALL UNTIL THE STATION, BEND & TUBING TO STATION, ELECTRICAL & ETHERNET CONNECTIONS ARE COMPLETED. DO NOT REMOVE PROTECTIVE COVER (PLYWOOD/METAL) UNTIL AFTER DRYWALL IS INSTALLED AND PAINTED. PEVCO WILL REMOVE THE COVER AND INSTALL THE TRIM FRAME.
6. CARRIER DISPATCH MOVES FROM REAR TO FRONT.
7. STATION WEIGHT IS 165 LBS.



1401 Tangier Drive
 Baltimore, Maryland 21220
 T 410.931.8800, F 410.931.4660
 800.296.PEVCO (7382), www.pevco.com

BEAM WALL RECESSED HIGH CAPACITY STATION

SCALE	NONE	DATE
DRAWN	SDW	06.01.20
REVISED	-	-
	-	-
DRAWING NUMBER	PEV200.50	REVISION 0

6" COMPUTERIZED PNEUMATIC TUBE SYSTEMS